

## Self-inspection checklist

---

### Floor and wall openings

- Are floor holes or openings guarded by a cover, guardrail, or equivalent on all sides (except at entrance to stairways or ladders)?
- Are toeboards installed around the edges of a permanent floor opening (where persons may pass below the opening)?
- Are skylight screens constructed and mounted to withstand a load of at least 200 pounds?
- Is the glass in windows, doors, and glass walls which may be subject to human impact appropriate for its use?
- Are grates or similar covers over floor openings such as floor drains designed so that the grate spacing will not catch foot traffic or rolling equipment?
- Are unused service pits and portions of such pits covered or protected by guardrails or the equivalent?