

Self-inspection checklist

Walkways

- Are aisles and passageways kept clear and at least 22 inches wide?
- Are aisles and walkways appropriately marked?
- Are wet surfaces covered with non-slip materials?
- Are openings or holes in the floors or other walking surfaces repaired or otherwise made safe?
- Is there a safe clearance for walking in aisles in which vehicles operate?
- Are materials and equipment stored so sharp objects do not obstruct the walkway?
- Are changes of direction or elevation easily identified?
- Do aisles or walkways near moving or operating machinery, welding, and similar operations keep employees away from hazards?
- Is there floor-to-headroom height of at least 6.5 feet provided for the entire length of any walkway?
- Are standard guardrails provided wherever aisle or walkway surfaces are elevated more than four feet above floor or ground?
- Are bridges provided over conveyors and similar hazards?